

ਦਫਤਰ ਨਗਰ ਪੰਚਾਇਤ, ਸਰਦੂਲਗੜ੍ਹ, ਮਾਨਸਾ।

eonpsardulgarh2012@gmail.com

ਨੰ: 675

ਮਿਤੀ 8/5/2025

ਵੱਲ:

ਪ੍ਰਿੰਸੀਪਲ, (97806-70234)

ਰੋਇਲ ਕਾਨਵੈਂਟ ਸਕੂਲ,

ਸਰਦੂਲਗੜ੍ਹ।

ਵਿਸ਼ਾ:-

Request for Issuance of Health and Sanitary Certificate for Royal

Convent School, Sardulgarh.

ਹਵਾਲਾ:-


ਆਪ ਦੇ ਅਦਾਰੇ ਦਾ ਪੱਤਰ ਨੰ: RCS/25/211 ਮਿਤੀ 05/05/2025

ਸ਼੍ਰੀਮਾਨ/ਸ਼੍ਰੀਮਤੀ ਜੀ,

ਉਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਆਪ ਪਾਸੋਂ ਪ੍ਰਾਪਤ ਬਿਨੈ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਦਫਤਰ ਨਗਰ ਪੰਚਾਇਤ, ਸਰਦੂਲਗੜ੍ਹ ਦੇ ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ ਵੱਲੋਂ ਆਪ ਦੇ ਅਦਾਰੇ ਦੀ ਚੈਕਿੰਗ ਕੀਤੀ ਗਈ, ਜਿਸ ਅਧੀਨ ਹੇਠ ਲਿਖੇ ਅਨੁਸਾਰ ਤਰ੍ਹਾਂ-ਤਰ੍ਹਾਂ ਪਾਈਆਂ ਗਈਆਂ ਹਨ, ਜਿਨ੍ਹਾਂ ਨੂੰ ਦੂਰ ਕਰਨ ਉਪਰੰਤ ਹੀ ਆਪ ਦੇ ਅਦਾਰੇ ਨੂੰ ਸਿਹਤ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਸਰਟੀਫਿਕੇਟ ਇਸ ਆਧਾਰ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ।

- 1) ਇਹ ਕਿ ਆਪ ਦੇ ਅਦਾਰੇ ਵੱਲੋਂ ਜੋ ਕੂੜਾ ਖਾਲੀ ਪਲਾਟ ਵਿੱਚ ਸੁੱਟਿਆ ਜਾਂਦਾ ਹੈ ਉਸ ਦਾ ਨਿਪਟਾਰਾ ਗਿੱਲੇ ਅਤੇ ਸੁੱਕੇ ਰੂਪ ਵਿੱਚ ਨਗਰ ਪੰਚਾਇਤ, ਸਰਦੂਲਗੜ੍ਹ ਪਾਸੋਂ ਹਫਤਾਵਾਰੀ ਟਰਾਲੀ ਮੰਗਵਾ ਕੇ ਮਹੀਨੇ ਬਾਅਦ ਬਣਦੇ ਯੂਜ਼ਰ ਚਾਰਜਿਜ਼ ਅਦਾ ਕਰਕੇ ਰਸੀਦ ਪ੍ਰਾਪਤ ਕੀਤੀ ਜਾਵੇ।
 - 2) ਇਹ ਕਿ ਆਪ ਵੱਲੋਂ ਆਪਣੇ ਅਦਾਰੇ ਦਾ ਜੋ ਵੇਸਟ ਨਿਕਾਸੀ ਵਾਲਾ ਪਾਣੀ ਸੈਪਟਿਕ ਟੈਂਕ ਰਾਹੀਂ ਇੱਕਠਾ ਕਰਵਾ ਕੇ ਪ੍ਰਾਈਵੇਟ ਡੀਸੱਲਜਰ ਤੋਂ ਡੀਸੱਲਜ ਕਰਵਾਇਆ ਜਾਂਦਾ ਹੈ, ਉਸ ਬਾਬਤ ਇਹ ਯਕੀਨੀ ਬਣਾਇਆ ਜਾਵੇ ਕਿ ਸਬੰਧਿਤ ਡੀਸੱਲਜਰ ਵੱਲੋਂ ਰੂਲਾਂ/ਹਦਾਇਤਾਂ ਅਨੁਸਾਰ ਨਗਰ ਪੰਚਾਇਤ, ਸਰਦੂਲਗੜ੍ਹ ਦੇ ਸੀਵਰੇਜ ਵਿੱਚ ਹੀ ਡੀਸੱਲਜ ਕੀਤਾ ਜਾਵੇ। ਉਪਰੰਤ ਡੀਸੱਲਜਿੰਗ ਉਸਦੀ ਜੀ.ਪੀ.ਐੱਸ. ਵੀਡੀਓ ਇਸ ਦਫਤਰ ਨੂੰ ਹਰ ਵਾਰ (82830-41200) ਤੇ ਵੱਟਸਅਪ ਕੀਤੀ ਜਾਵੇ। ਇਸ ਤੋਂ ਵੱਖ ਸਾਰੇ ਵੇਸਟ ਪਾਣੀ ਦੀ ਨਿਕਾਸੀ ਸੀਵਰੇਜ ਦਾ ਕੁਨੈਕਸ਼ਨ ਲੈ ਕੇ ਉਸ ਵਿੱਚ ਹੀ ਕਰਵਾਈ ਜਾਵੇ।
 - 3) ਇਹ ਕਿ ਬੱਚਿਆਂ ਦੇ ਪੀਣ ਵਾਲੇ ਪਾਣੀ ਦੇ ਵਾਟਰ ਕੂਲਰ ਦੇ ਆਲੇ-ਦੁਆਲੇ ਨਿਕਾਸੀ ਪਾਣੀ ਇੱਕਠਾ ਨਾ ਹੋਣ ਦਿੱਤਾ ਜਾਵੇ ਤਾਂ ਜੋ ਡੋਂਗੂ/ਮਲੇਰੀਆ ਮੱਛਰਾਂ ਦੀ ਪੈਦਾਵਾਰ ਨਾ ਹੋ ਸਕੇ। ਉਕਤ ਪਾਣੀ ਨੂੰ ਬੂਟਿਆਂ/ਪੌਦਿਆਂ ਨੂੰ ਪਾ ਕੇ ਵਰਤੋਂ ਵਿੱਚ ਲਿਆਂਦਾ ਜਾ ਸਕਦਾ ਹੈ।
 - 4) ਇਹ ਕਿ ਹਰ ਸ਼ੁੱਕਰਵਾਰ/ਸ਼ਨੀਵਾਰ ਡਰਾਈ ਡੇ ਮਨਾਇਆ ਜਾਵੇ। ਜੇਕਰ ਸਕੂਲ ਦੀ ਹਦੂਦ ਅੰਦਰ ਕਿਤੇ ਵੀ ਪਾਣੀ ਆਦਿ ਖੜ੍ਹਾ ਹੈ, ਉਸ ਦੀ ਡੀਵਾਟਰਿੰਗ ਕੀਤੀ ਜਾਵੇ ਅਤੇ ਲੋੜ ਪੈਣ ਤੇ ਸਿਹਤ ਵਿਭਾਗ ਦੀਆਂ ਸੇਵਾਵਾਂ ਲਈਆਂ ਜਾਣ ਅਤੇ ਲੋੜੀਂਦੇ ਇੰਸੈਕਟੀਸਾਈਟਸ ਦੀ ਵਰਤੋਂ ਕੀਤੀ ਜਾਵੇ।
 - 5) ਇਹ ਕਿ ਜੇਕਰ ਸਕੂਲ ਵਿੱਚ ਵਿਦਿਆਰਥਣਾਂ/ਮਹਿਲਾ ਸਟਾਫ ਵੱਲੋਂ ਸੈਨੇਟਰੀ ਪੈਡਸ ਦੀ ਵਰਤੋਂ ਕੀਤੀ ਜਾਂਦੀ ਹੈ ਤਾਂ ਉਸ ਦਾ ਵੀ ਰੂਲਾਂ/ਹਦਾਇਤਾਂ ਅਨੁਸਾਰ ਨਿਪਟਾਰਾ ਕੀਤਾ ਜਾਵੇ।
- ਉਪਰੋਕਤ ਅਨੁਸਾਰ ਕੰਮਾਂ ਸਬੰਧੀ ਕਿਸੇ ਵੀ ਕਿਸਮ ਦੀ ਜਾਣਕਾਰੀ ਬਾਬਤ ਇਸ ਦਫਤਰ ਦੇ ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ ਨਾਲ ਤਾਲਮੇਲ ਕੀਤਾ ਜਾਵੇ। ਇਹ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਹੋਣ ਦੀ ਮਿਤੀ ਤੋਂ ਲੈ ਕੇ ਇੱਕ ਸਾਲ ਤੱਕ ਲਈ ਵੈਧ ਹੋਵੇਗਾ।


Headmistress
Royal Convent School
Sardulgarh (Mansa)



ਕਾਰਜ ਸਾਧਕ ਅਫਸਰ,
ਨਗਰ ਪੰਚਾਇਤ, ਸਰਦੂਲਗੜ੍ਹ।

Office of the Nagar Panchayat, Sardulgarh, Mansa.

conpsardulgarh2012@gmail.com

No 675

Principal (97806-70234)
Royal Convent School
Sardulgarh.



Date 8/5/2025

Subject :-Request for Issuance of Health and Sanitary Certificate for Royal Convent School Sardulgarh

Reference No: Office Order Latter No RCS/25/211 Date 05/05/2025

Mr./Mrs.

In connection with the application received from you regarding the above subject, the Sanitary Inspector of the Office of Nagar Panchayat, Sardulgarh, checked your establishment, under which the following deficiencies have been found. Only after removing which, a health and sanitation certificate is issued to your establishment on this basis.

1. That the waste dumped by your institution in the empty plant should be disposed of in wet and dry form by ordering a weekly trolley from the Nagar Panchayat, Sardulgarh and a receipt should be obtained after paying the user charges due after the month.
2. That the waste water of your institution which is collected through septic tank and desilted by private deciliter, should be ensured that the concerned desilter should desalt in the sewerage of Nagar Panchayat, Sardulgarh as per the rules/instructions. After that, the GPS video of desilting should be Whats Apped to this office every time on (82830-41200). Apart from this, all the waste water should be drained by taking a sewerage connection and done in it.
3. That the drain water should not be allowed to accumulate around the water cooler of the children's drinking water so that dengue/malaria mosquitoes cannot breed. The said water can be used by watering the plants/herbs.
4. That every Friday/Saturday be observed as a dry day. If there is standing water anywhere within the school premises, it should be dewatered and if necessary, the services of the health department should be taken and necessary insecticides should be used.
5. That if sanitary pads are used by female students/staff in the school, they should also be disposed of as per the rules/instructions.
6. Any information regarding the above works should be coordinated with the Sanitary Inspector of this office. This certificate will be valid for one year from the date of issue.

This document is
Presented before me by
execution of the
Documentary evidence &
explained to me & I
have accepted it to be correct

Head Mistress
Royal Convent School
Sardulgarh (Mansa)

Attested as Identified
SANT RAM GURWAN
NOTARY
Distt. Mansa (Pb.)

9.6.2025

Practicing Officer, Nagar
Panchayat, Sardulgarh.

certified that this Certificate/Document
is TRANSLATED From Punjabi
Language to English Language US
8(1)(h) of Notaries act 1952 India

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmanasa@gmail.com

To,

ROYAL CONVENT SCHOOL
OLD CINEMA ROAD, SARDULGARH


No.: DWTL/MNS/2526/00005 Dated : 17/04/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. RCS/25/194 Dated: 04/04/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 07/04/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Mansa



Head Mistress
Royal Convent School
Sardulgarh (Mansa)

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmanasa@gmail.com



TC-11388

TEST REPORT

Name & Address of Customer : ROYAL CONVENT SCHOOL OLD CINEMA ROAD,SARDULGARH		Customer Reference No.	No : RCS/25/194 Dated : 04/04/2025
		Sample Submitted by	MR.SITA RAM
		Date of Sample Receipt	07/04/2025
		Analysis Starting Date	15/04/2025
		Analysis completion Date	16/04/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC113862500000002F	Sample Type :	Water
Test Report No.:	DWTL/MNS/2526/00005	Date of Issue :	17/04/2025
Registration no.:	DWTL/MNS/REG2526/00007	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	OLD CINEMA ROAD,SARDULGARH,MANSA / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Mansa
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.09@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	03	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	14	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	34	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	16	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	5.61	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	0.48	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	16.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

Komal Sharma
Head Mistress
Royal Convent School
Sardulgarh (Mansa)

----- End of the Test Report -----